

**Installation Manual**

**Square Beam Load Cell LC Nito PR 79, PR 79T**



## **Foreword**

### **Must be followed!**

Any information in this document is subject to change without notice and does not represent a commitment on the part of Minebea Intec unless legally prescribed. This product should only be operated/installed by trained and qualified personnel. In correspondence concerning this product, the type, name, and release number/serial number as well as all license numbers relating to the product have to be cited.

### **Note**

This document is partially protected by copyright. It may not be changed or copied, and it may not be used without purchasing or written permission from the copyright owner (Minebea Intec). The use of this product constitutes acceptance by you of the abovementioned provisions.

## Table of contents

<b>1</b>	<b>Introduction</b>	<b>3</b>
1.1	Read the manual	3
1.2	This is what operating instructions look like	3
1.3	This is what lists look like	3
1.4	This is what menu items and softkeys look like	3
1.5	This is what the safety instructions look like	3
1.6	Hotline	4
<b>2</b>	<b>Safety instructions</b>	<b>5</b>
2.1	General notes	5
2.2	Intended use	5
2.3	Initial inspection	5
2.4	Before operational startup	5
<b>3</b>	<b>Specifications</b>	<b>6</b>
3.1	Equipment supplied with the load cell	6
3.2	General information	6
3.3	Possible marking of the load cell for the Ex area	7
3.4	Dimensions	8
3.5	Ordering information	12
3.6	Technical data	13
<b>4</b>	<b>Installation</b>	<b>16</b>
4.1	Safety instructions	16
<b>5</b>	<b>Connection</b>	<b>17</b>
5.1	General information	17
5.2	Load cell	18
5.3	Load cell cable	18
5.4	Cable gland	19
<b>6</b>	<b>Maintenance/repairs/cleaning</b>	<b>20</b>
6.1	Maintenance	20
6.2	Repairs	20
6.3	Cleaning	20
<b>7</b>	<b>Disposal</b>	<b>21</b>
<b>8</b>	<b>Accessories</b>	<b>22</b>
8.1	Mounting kits	22
<b>9</b>	<b>Certificates</b>	<b>23</b>
9.1	CE-00055A	24

9.2	17-124.....	30
9.3	10101.....	33
9.4	R60/2000-NL1-17.55.....	34
9.5	TC11073.....	36
9.6	BVS 21 ATEX E 023X.....	39
9.7	IECEX BVS 21.0024X.....	47

# 1 Introduction

## 1.1 Read the manual

- Please read this manual carefully and completely before using the product.
- This manual is part of the product. Keep it in a safe and easily accessible location.

## 1.2 This is what operating instructions look like

1. - n. are placed before steps that must be done in sequence.
  - ▶ is placed before a step.
  - ▷ describes the result of a step.

## 1.3 This is what lists look like

- indicates an item in a list.

## 1.4 This is what menu items and softkeys look like

[ ] frame menu items and softkeys.

**Example:**

[Start]- [Applications]- [Excel]

## 1.5 This is what the safety instructions look like

Signal words indicate the severity of the danger involved when measures for preventing hazards are not followed.

### **DANGER**

#### **Warning of personal injury**

DANGER indicates death or severe, irreversible personal injury which will occur if the corresponding safety measures are not observed.

- ▶ Take the corresponding safety precautions.

### **WARNING**

#### **Warning of hazardous area and/or personal injury**

WARNING indicates that death or severe, irreversible injury may occur if appropriate safety measures are not observed.

- ▶ Take the corresponding safety precautions.

### **CAUTION**

#### **Warning of personal injury.**

CAUTION indicates that minor, reversible injury may occur if appropriate safety measures are not observed.

- ▶ Take the corresponding safety precautions.

**NOTICE****Warning of damage to property and/or the environment.**

NOTICE indicates that damage to property and/or the environment may occur if appropriate safety measures are not observed.

- ▶ Take the corresponding safety precautions.
- 

**Note:**

User tips, useful information, and notes.

---

## 1.6 Hotline

Phone: +49.40.67960.444

Fax: +49.40.67960.474

eMail: [help@minebea-intec.com](mailto:help@minebea-intec.com)

## 2 Safety instructions

### 2.1 General notes

#### NOTICE

##### **Warning of damage to property and/or the environment.**

The product was in perfect condition with regard to safety features when it left the factory.

- ▶ To maintain this condition and to ensure safe operation, the user must follow the instructions and observe the warnings in this manual.

### 2.2 Intended use

The load cells are designed for use in hopper and platform scales.

The load cells PR 79, PR 79T may only be used as intended for weighing tasks.

In intrinsically safe circuits, only load cells PR 79/..E, PR 79T/..E may be used.

The dimensions of all mounting and structural components must be calculated so that sufficient overload capacity is ensured for all loads which may occur while taking the relevant standards into account. In particular, upright weighing objects must be safeguarded against the weighing installation turning over or being shifted, thus eliminating danger to people, animals, or goods even in the case of a break in a load cell or mounting element.

Installation and repair work must only be carried out by expert/qualified personnel.

The load cells reflect the state of the art. The manufacturer does not accept any liability for damage caused by third-party system components or due to incorrect use of the product.

### 2.3 Initial inspection

Check the contents of the consignment for completeness. Check the contents visually to determine whether any damage has occurred during transport. If there are grounds for rejection of the goods, a claim must be filed with the carrier immediately. The Minebea Intec sales or service organization must also be notified.

### 2.4 Before operational startup

#### NOTICE

##### **Perform visual inspection.**

- ▶ Before operational startup as well as after storage or transport, inspect the load cell visually for signs of mechanical damage.
- ▶ The load cell should not be commissioned if it displays signs of visible damage and/or is defective.

## 3 Specifications

### 3.1 Equipment supplied with the load cell

No.	Description
1	Load cell
2	Quick guide
3	Calibration Certificate
4	Only with Ex-load cells: Safety information for PR xx series

### 3.2 General information

Material	Stainless steel
Protection classes	<p>in compliance with IEC 529 or DIN EN 60529</p> <p><b>IP68/IP69:</b> Dust-proof and leak-tight against water, with harmful effects when immersed, (1.5 m water depth, 10,000 h) and water jets (high pressure and temperature).</p> <p>only PR 79/91 kg, PR 79T/91 kg:</p> <p><b>IP66/IP67:</b> Dust-proof and leak-tight against water, with harmful effects when immersed, (1 m water depth, 30 minutes).</p> <p><b>Explosion:</b> Suitable for explosion subgroup IIC and IIIC.</p>
EMC	High frequency electromagnetic fields acc. to EN 61000-4-3 10 V/m
Cable diameter	5 mm
Cable length	see data sheet
Cable gauge	6x0.14 mm <sup>2</sup>
Cable bend radius	<p>≥25 mm (fixed installation)</p> <p>≥75 mm (flexible installation)</p>
Cable sheath material	Thermoplastic elastomer (TPE)
Cable sheath color	Green, Ex version with blue marking

### 3.3 Possible marking of the load cell for the Ex area

Zone	Marking	Certificate no.	for
0	II 1G Ex ia IIC T6/T4 Ga Ex ia IIC T6/T4 Ga	BVS 21 ATEX E 023 X IECEX BVS 21.0024 X	only PR 7x/..E
20	II 1D Ex ia IIIC T <sub>200</sub> 165°C Da Ex ia IIIC T <sub>200</sub> 165°C Da	BVS 21 ATEX E 023 X IECEX BVS 21.0024 X	only PR 7x/..E
2	II 3G Ex ec IIC T6/T4 Gc Ex ec IIC T6/T4 Gc	BVS 21 ATEX E 023 X IECEX BVS 21.0024 X	all PR 7x without /..E
21	II 2D Ex tb IIIC T110°C Db Ex tb IIIC T110°C Db	BVS 21 ATEX E 023 X IECEX BVS 21.0024 X	all PR 7x without /..E

#### NOTICE

##### Installation in the Ex area

- ▶ For installations in the Ex area, it is imperative to observe the Ex safety instructions in the installation manuals.

#### ⚠ WARNING


##### Warning of hazardous area and/or personal injury

When used in a dust ex zone, the risk of electrostatic charging must be minimized.

- ▶ Dust layers on the load cell >5 mm are not permitted.
- ▶ The load cell must be installed securely.


### 3.4 Dimensions

#### PR 79/91 kg



all dimensions in mm


**PR 79/..**



all dimensions in mm


<b>Model</b>	<b>A</b>
PR 79/227 kg	28.8
PR 79/454 kg	28.8
PR 79/1134 kg	30.5
PR 79/1760 kg	30.5
PR 79/2268 kg	30.5

**PR 79T/91 kg**



all dimensions in mm

**PR 79T/..**



all dimensions in mm

Model	A	B	C	D	E	F	G	H	I	J	K	L
PR 79T/227 kg	133.4	31	30	60	12.7	76.2	25.4	28.8	∅13	∅18	4	15.0
PR 79T/454 kg	133.4	31	30	60	12.7	76.2	25.4	28.8	∅13	∅18	4	15.0
PR 79T/1134 kg	133.4	31	30	60	12.7	76.2	25.4	28.8	∅13	∅18	4	15.0
PR 79T/1760 kg	133.4	31	30	60	12.7	76.2	25.4	28.8	∅13	∅18	4	15.0
PR 79T/2268 kg	133.4	31	30	60	12.7	76.2	25.4	28.8	∅13	∅18	4	15.0
PR 79T/5099 kg	190.0	49	43	93	21.0	105	40.0	41.0	∅21	∅25	8	20.5

### 3.5 Ordering information

#### PR 79

<b>Model</b>	<b>Max. capacity <math>E_{max}</math></b>	<b>Type OIML/NTEP</b>	<b>Type Ex</b>
PR 79/91 kg	91 kg	..C3MR	..C3MRE
PR 79/227 kg	227 kg	..C3MR	..C3MRE
PR 79/454 kg	454 kg	..C3MR	..C3MRE
PR 79/1134 kg	1.134 t	..C3MR	..C3MRE
PR 79/1760 kg	1.760 t	..C3MR	..C3MRE
PR 79/2268 kg	2.268 t	..C3MR	..C3MRE

#### PR 79T

<b>Model</b>	<b>Max. capacity <math>E_{max}</math></b>	<b>Type OIML/NTEP</b>	<b>Type Ex</b>
PR 79T/91 kg	91 kg	..C3MR	..C3MRE
PR 79T/227 kg	227 kg	..C3MR	..C3MRE
PR 79T/454 kg	454 kg	..C3MR	..C3MRE
PR 79T/1134 kg	1.134 t	..C3MR	..C3MRE
PR 79T/1760 kg	1.760 t	..C3MR	..C3MRE
PR 79T/2268 kg	2.268 t	..C3MR	..C3MRE
PR 79T/5099 kg	5.099 t	..C3MR	..C3MRE

### 3.6 Technical data

Designation	Description	Abbr.	C3MR	Unit
Accuracy class			0.02	% E <sub>max</sub>
Minimum dead load	lowest limit of specified measuring range	E <sub>min</sub>	0	% E <sub>max</sub>
Maximum capacity	highest limit of specified measuring range	E <sub>max</sub>	see Chapter 3.5	
Safe load limit	maximum load without irreversible damage	E <sub>lim</sub>	150	% E <sub>max</sub>
Destructive load	danger of mechanical destruction	E <sub>d</sub>	300	% E <sub>max</sub>
Minimum LC verification	minimum load cell scale interval, $v_{min} = E_{max}/Y$	Y	12000	
Minimum preload signal recurrence	recurrence of the minimum preload signal ( $DR = 1/2 \times E_{max}/Z$ )	Z	3000	
Rated output	relative output at maximum capacity	C <sub>n</sub>	2	mV/V
Tolerance on rated output	permissible deviation from rated output C <sub>n</sub>	d <sub>c</sub>	±0.07	% C <sub>n</sub>
Zero output signal	load cell output signal under unloaded condition	S <sub>min</sub>	0 ±1	% C <sub>n</sub>
Repeatability	max. change in load cell output for repeated loading	ε <sub>R</sub>	<0.0100	% C <sub>n</sub>
Creep	max. change of output signal at E <sub>max</sub> during 30 minutes	d <sub>cr</sub>	<0.0166	% C <sub>n</sub>
Non-linearity <sup>1)</sup>	deviation from best straight line through zero	d <sub>Lin</sub>	<0.0166	% C <sub>n</sub>
Hysteresis <sup>1)</sup>	max. difference in LC output between loading and unloading	d <sub>hy</sub>	<0.0166	% C <sub>n</sub>
Temperature effect on S <sub>min</sub>	max. change of S <sub>min</sub> per 10 K in ambient temperature range	TK <sub>Smin</sub>	<0.0117	% C <sub>n</sub> /10 K
Temperature effect on C <sup>1)</sup>	max. change of C per 10 K in ambient temperature range	TK <sub>C</sub>	<0.0117	% C <sub>n</sub> /10 K
Input impedance	between supply terminals	R <sub>LC</sub>	1100 ±10	Ω
Output impedance	between measuring terminals	R <sub>O</sub>	1000 ±1	Ω
Insulation impedance	between measuring circuit and housing at U <sub>DC</sub> = 100 V	R <sub>IS</sub>	>5000	MΩ
Recommended supply voltage	to hold the specified performance	B <sub>u</sub>	≤12	V
Max. supply voltage	permissible for continuous operation without damage	U <sub>max</sub>	15	V

Designation	Description	Abbr.	C3MR	Unit
Nominal ambient temp. range	to hold the specified performance	B <sub>T</sub>	-10...+40	°C
Usable ambient temp. range	permissible for continuous operation without damage	B <sub>Tu</sub>	-40...+80	°C
Storage temperature range	without electrical and mechanical stress	B <sub>Ti</sub>	-40...+80	°C
Barometric pressure influence	influence of barometric pressure on output		<0.003	% C <sub>n</sub> /kPa
Nominal deflection	elastic deformation under max. capacity	s <sub>nom</sub>		
	91...1760 kg		<0.3	mm
	2268 kg		<0.5	mm
	5099 kg		<0.6	mm

- 1) The data for non-linearity (d<sub>Lin</sub>), hysteresis (d<sub>hy</sub>) and and temperature effect on C (TKC) are typical values.  
For OIML R60 or NTEP approved load cells the sum of these values is within the permissible cumulative error limits.

Definitions acc. to OIML R60

The technical data given are intended solely as a product description and should not be interpreted as guaranteed properties in the legal sense.

**Accuracy classes and min. scale interval of the load cells  $v_{min}$  for PR 79/..**

<b>PR 79</b>	<b>Type</b>	<b>Divisions <math>n_{max}</math></b>	<b>91 kg</b>	<b>227 kg</b>	<b>454 kg</b>	<b>1134 kg</b>	<b>1760 kg</b>	<b>2268 kg</b>	<b>Unit</b>
OIML	C3MR	3000	7.6	18.9	37.8	94.5	146.6	189.0	g
NTEP Class III Single	C3MR	3000	7.6	18.9	37.8	94.5	146.6	189.0	g
NTEP Class III Multiple	C3MR	5000	7.6	18.9	37.8	94.5	146.6	189.0	g
NTEP Class III L Multiple	C3MR	10000	2.5	6.3	12.6	31.5	48.9	63.0	g

**Accuracy classes and min. scale interval of the load cells  $v_{min}$  for PR 79T/..**

<b>PR 79T</b>	<b>Type</b>	<b>Divisions <math>n_{max}</math></b>	<b>91 kg</b>	<b>227 kg</b>	<b>454 kg</b>	<b>1134 kg</b>	<b>1760 kg</b>	<b>2268 kg</b>	<b>5099 kg</b>	<b>Unit</b>
OIML	C3MR	3000	7.6	18.9	37.8	94.5	146.6	189.0	424.9	g
NTEP Class III Single	C3MR	3000	7.6	18.9	37.8	94.5	146.6	189.0	424.9	g
C3MR Class III Multiple	C3MR	5000	7.6	18.9	37.8	94.5	146.6	189.0	424.9	g
C3MR Class III L Multiple	C3MR	10000	2.5	6.3	12.6	31.5	48.9	63.0	141.6	g

## 4 Installation

### 4.1 Safety instructions

#### NOTICE

**Welding or lightning strike current flowing through the cell can damage it.**

All electrical welding on the weighing system must be finished before mounting the load cells.

During any additional electrical welding work near the load cell:

- Disconnect the load cell cables.
- Bypass the load cell.
- Make sure that the grounding clamp of the welding set is fitted as closely as possible to the welding joint.

The following must be observed during installation:

- Do not lift or transport the load cell by pulling on the cable.
- Avoid shock stress (falling down, hard shocks).
- Load forces must act in the direction indicated (arrow on the load cell).
- Installation with a spacer, such as PR 98/0xS, is recommended due to the nominal deflection.

#### NOTICE

**Changes of temperature >15 K/h may influence the measuring accuracy.**

- ▶ Make sure to protect the load cells from direct heating or cooling effects (sun, wind, heat radiation, fan heaters), e.g., heat protection screens or heat protection housings are to be installed if necessary.

#### NOTICE

**Force shunts may cause measuring errors.**

- ▶ All incoming and outgoing lines (hoses, pipes, cables) must be coupled to the measured object as flexibly as possible.

## 5 Connection

### 5.1 General information

- Protect the cable ends against contamination. Moisture must not get into the open end of the cable.
- Keep the load cell cables away from power cables.
- The distance between measurement cables and power cables and/or components under high voltage should be at least 1 m (reference value).
- We recommend laying the load cell cables in separate cable trays or armored steel pipes.
- Power cables should be crossed at right angles while taking into account the minimum distance of 1 m (reference value).

---

**Note:**

If hum interference occurs, the cable screens should only be connected on one side.

Depending on the design of the cable junction box used, either the jumper J3 must be removed or the cable screens must be disconnected from the terminal contacts highlighted in yellow.

---

**⚠ WARNING****When installing in potentially explosive atmospheres:**


It is imperative that you follow the application-dependent installation instructions!

- ▶ Always check whether it is permissible to bilaterally connect the screens to the equipotential bonding.
-

## 5.2 Load cell

### Color code

bk	=	black
bu	=	blue
gn	=	green
gy	=	gray
rd	=	red
wh	=	white



## 5.3 Load cell cable


The load cell cables are inseparably connected to the load cells in the factory.

The special sheathing material and the integrated strain relief with Kevlar thread ensure extremely long service life even under difficult operating conditions.

However, despite the robust nature of the materials used, the cable should be protected from excessive chemical and mechanical stresses. Preventing water from penetrating the end of the cable is also important "life insurance" for the system.

## 5.4 Cable gland

The cable gland is screwed to the load cell.



1. Screw the metal sleeve (1) into the load cell and fasten with a tightening torque of 3 Nm.
2. Screw the nut (2) into the metal sleeve and fasten with a tightening torque of 3 Nm.

## 6 Maintenance/repairs/cleaning

### 6.1 Maintenance

The load cells PR 79, PR 79T are maintenance-free.

### 6.2 Repairs

The load cells PR 79, PR 79T are designed to be robust as possible for the required measuring accuracy and are highly reliable.

Should an electrical or mechanical defect nevertheless occur, the load cell must be replaced.

Load cell repair is not possible.

### 6.3 Cleaning

Dirt on the load cell and movable parts of the scale must be cleaned as quickly as possible

- if it influences weighing, or
- if it is corrosive to the cell or cable material.

#### **NOTICE**

**Some cleaning agents may not be compatible with the load cell material.**

- ▶ When using cleaning agents, ensure that their compatibility with the load cell material has been tested and approved (see Chapter [3.2](#)).
- 

Clean the load cell with a damp cloth to avoid electrostatic charging.

## 7 Disposal

Our products and their packaging should not be disposed of in municipal waste (e.g. garbage can for recyclable packaging, garbage can for paper packaging, etc.). They can either be recycled by the customer themselves, providing this complies with requirements set out by electrical or electronic waste or packaging waste laws, or sent back to Minebea Intec at a charge.

This option of returning the product is intended to provide proper recycling or reuse in a manner that is collected separately from municipal waste.

Before disposing of or scrapping the old products, any single-use or rechargeable batteries should be removed and taken to a suitable collection point. The type of battery used is specified in the technical data.

Please see our General Terms and Conditions for further information.

Service addresses for repair acceptance and collection points can be found on the product information enclosed with the product as well as on our website ([www.minebea-intec.com](http://www.minebea-intec.com)).

Should you have any further questions, please contact your local service representative or our service center.

Minebea Intec GmbH

Repair center

Meiendorfer Strasse 205 A

22145 Hamburg, Germany

Phone: +49.40.67960.333

[service.HH@minebea-intec.com](mailto:service.HH@minebea-intec.com)

We reserve the right not to accept products that are contaminated with hazardous substances (ABC contamination).

## 8 Accessories

### 8.1 Mounting kits

To install the load cell, the following mounting kits / pivots are recommended:

No.	Description	Max. capacity	Order no.
1	Platform feet PR 91/00S	91...2268 kg	9405 300 91002
2	Platform feet PR 91T/00S	91...2268 kg	9405 300 91004
3	Platform feet PR 91T/01S	5099 kg	9405 300 91014
4	Mounting kit with elastomer support PR 92/00N	91...2268 kg	9405 300 92001
5	Maxi FLEX PR 95T/00S	91...2268 kg	9405 300 95004
6	Maxi FLEX PR 95T/01S	5099 kg	9405 300 95014
7	Maxi FLEX LOCK PR 95T/10S	91...2268 kg	9405 300 95104
8	Maxi FLEX LOCK PR 95T/11S	5099 kg	9405 300 95114
9	Spacer PR 98/00S	91...2268 kg	9405 300 98002
10	Spacer PR 98/01S	5099 kg	9405 300 98012


N = steel zinc plated, passivated and sealed (RoHS-compliant)

S = stainless steel

## 9 Certificates


<b>Ser. no.</b>	<b>Description</b>	<b>Document no.</b>	<b>see Chapter</b>
1	EU-Declaration of Conformity	CE-00055A	<a href="#">9.1</a>
2	Certificate of Conformance (NTEP)	17-124	<a href="#">9.2</a>
3	Certificate of Approval (NTEP-New York)	10101	<a href="#">9.3</a>
4	OIML Certificate of Conformity (NMI)	R60/2000-NL1-17.55	<a href="#">9.4</a>
5	Parts Certificate/Test Certificate (NMI)	TC11073	<a href="#">9.5</a>
6	EC-Type Examination Certificate	BVS 21 ATEX E 023X	<a href="#">9.6</a>
7	Certificate of Conformity	IECEX BVS 21.0024X	<a href="#">9.7</a>

9.1 CE-00055A



CE-00055A

## EU-Declaration of Conformity



*Passion to Create Value through Difference*

1. Product model / product number:  

Single Point Type Load Cell / PR 79, M110
---
  
2. Name and address of the manufacturer (2.1) and his authorized representative (2.2):
 

2.1 MinebeaMitsumi Inc. Sensing Device Business Unit, 1-1-1 Katase, Fujisawa-shi, Kanagawa, Japan
2.2 /
  
3. This declaration of conformity is issued under the sole responsibility of the manufacturer.
  
4. Object(s) of the declaration:
 


4.1 PR 79-***** M110-*****N***
4.2 PR 79-***** (A.1) M110-*****2***
4.3 PR 79-*****E M110-*****0***
  
5. The object(s) of the declaration described above is in conformity with the relevant Union harmonization legislation:
 

	(4.1)	(4.2)	(4.3)
5.1 2014/30/EU	(6.1)	(6.1)	(6.1)
5.2 2011/65/EU	(6.2)	(6.2)	(6.2)
5.3 2014/34/EU		(6.3)	(6.4)
  
6. References to the relevant harmonized standards used or references to the other technical specifications in relation to which conformity is declared:
 


6.1 2014/30/EU	EN 61326-1:2013
6.2 2011/65/EU	EN IEC 63000:2018
6.3 2014/34/EU	EN IEC 60079-0:2018, EN IEC 60079-7:2015+A1:2018, EN 60079-31:2014
6.4 2014/34/EU	EN IEC 60079-0:2018, EN 60079-11:2012
  
7. The notified body w performed x and issued the certificate y relevant for z:
 

	w	x	y	z
7.1 0158	EU-Type Examination Certificate		BVS 21 ATEX E 023 X	(4.2)(4.3)
7.2 0344	Production Quality Assessment Notification		DEKRA 17ATEXQ0031	(4.2)(4.3)

MinebeaMitsumi Inc.  
Fujisawa, 15. November. 2021



Satoshi Sato  
Division Head



Satoshi Uchibori  
CE Certification



1/6



### EU-Declaration of Conformity



A. Additional information on ( ):

A.1	(4.2)	Marking		II 3G Ex ec IIC T6/T4 Gc II 2D Ex tb IIIC T110°C Db BVS 21 ATEX E 023 X
A.2	(4.3)	Marking		II 1G Ex ia IIC T6/T4 Ga II 1D Ex ia IIIC T200 165°C Da BVS 21 ATEX E 023 X



# EU-Declaration of Conformity



**български (bg)**

Декларация за съответствие  
 1. Модел на продукта / Номер на продукта / илустрация само за номера на проекта:  
 2. Именното и адрес на производителя (2.1) и на неговия упълномощен представител (2.2);  
 3. Настоящата декларация за съответствие с извадена на отговорността на производителя.  
 4. Предмет(и) на декларацията;  
 5. Предмет(и) (ите) на декларацията, описан(и) по-горе отговаря(т) на съответното законодателство на Съюза за хармонизиране;  
 6. Позоваване на използваните хармонизираните стандарти или позоваване на други технически спецификации, по отношение на които се декларира съответствие;  
 7. Нотифицираният орган в извършил и издал сертификата Y, отнасящ се за:  
 A. Допълнителна информация за ( ):  
 A.1 Маркировка  
 A.2 Маркировка

**čeština (cs)**

Prohlášení o shodě  
 1. Model výrobku / číslo výrobku / platné pouze pro číslo projektu:  
 2. Jméno a adresa výrobce (2.1) a jeho zplnomocněného zástupce (2.2);  
 3. Toto prohlášení o shodě se vydává na výhradní odpovědnost výrobce.  
 4. Předmět(y) prohlášení;  
 5. Výše popsaný předmět / Výše popsané předměty prohlášení je/ jsou ve shodě s příslušnými harmonizačními právními předpisy Unie;  
 6. Odkazy na příslušné harmonizované normy, které byly použity, nebo na jiné technické specifikace, na jejichž základě se shoda prohlašuje;  
 7. Oznamovaný subjekt v provedl x a vydal certifikát y relevantní z hlediska z:  
 A. Další informace o ( ):  
 A.1 Označení  
 A.2 Označení

**dansk (da)**

Overensstemmelseserklæring  
 1. Produktmodel / produktnummer / gælder kun for projektnummer:  
 2. Fabrikantens (2.1) og dennes bemyndigede repræsentants (2.2) navn og adresse;  
 3. Denne overensstemmelseserklæring udstedes på fabrikantens ansvar.  
 4. Genstand(ene) for erklæringen;  
 5. Genstand(ene) for erklæringen, som beskrevet ovenfor, er i overensstemmelse med den relevante EU-harmoniseringslovgivning;  
 6. Referencer til de relevante anvendte harmoniserede standarder eller til de andre tekniske specifikationer, som der erklæres overensstemmelse med;  
 7. Det bemyndigede organ har foretaget x og udstedt attesten y, der gælder for z:  
 A. Supplerende oplysninger om ( ):  
 A.1 Markering  
 A.2 Markering

**Deutsch (de)**

Konformitätserklärung  
 1. Produktmodell / Produktnummer / gilt ausschließlich für Projekt-Nr.:  
 2. Name und Anschrift des Herstellers (2.1) und seines Bevollmächtigten (2.2);  
 3. Die alleinige Verantwortung für die Ausstellung dieser Konformitätserklärung trägt der Hersteller.  
 4. Gegenstände der Erklärung;  
 5. Die oben beschriebenen Gegenstände der Erklärung erfüllen die einschlägigen Harmonisierungsrechtsvorschriften der Union;  
 6. Angabe der einschlägigen harmonisierten Normen oder der anderen technischen Spezifikationen, die der Konformitätserklärung zugrunde gelegt wurden;  
 7. Die notifizierte Stelle w hat x und die für z relevante Bescheinigung y ausgestellt:  
 A. Zusatzangaben zu ( ):  
 A.1 Kennzeichnung  
 A.2 Kennzeichnung

**Ελληνικά (el)**

Δήλωση συμμόρφωσης  
 1. Μοντέλο προϊόντος / αριθμός προϊόντος / ισχύει μόνο για τον αριθμό του έργου:  
 2. Όνομα και διεύθυνση του κατασκευαστή (2.1) και του εξουσιοδοτημένου εκπροσώπου του (2.2);  
 3. Η παρούσα δήλωση συμμόρφωσης εκδίδεται με αποκλειστική ευθύνη του κατασκευαστή.  
 4. Στόχος της δήλωσης;  
 5. Ο στόχος της δήλωσης που περιγράφεται παραπάνω είναι σύμφωνος με τη σχετική ενοποιηκή νομοθεσία ενωμένης;  
 6. Παραπομπές στα σχετικά εναρμονισμένα πρότυπα που χρησιμοποιήθηκαν ή παραπομπές στις λοιπές τεχνικές προδιαγραφές σε σχέση με τις οποίες δηλώνεται η συμμόρφωση;  
 7. Ο κοινοποιημένος οργανισμός w διέκρινε x και εξέδωσε το πιστοποιητικό y όπως απαιτείται για z:  
 A. Πρόσθετες πληροφορίες σχετικά με ( ):  
 A.1 Σήμανση  
 A.2 Σήμανση

**español (es)**

Declaración de conformidad  
 1. Modelo de producto/número de producto / únicamente válido para el número de proyecto:  
 2. Nombre y dirección del fabricante (2.1) y de su representante autorizado (2.2);  
 3. La presente declaración de conformidad se expide bajo la exclusiva responsabilidad del fabricante.  
 4. Objeto(s) de la declaración;  
 5. El/Los objeto(s) de la declaración descritos anteriormente son conformes con la legislación de armonización pertinente de la Unión Europea;  
 6. Referencias a las normas armonizadas pertinentes utilizadas o referencias a las otras especificaciones técnicas respecto a las cuales se declara la conformidad;  
 7. El organismo notificado W ha efectuado X y expedido el certificado Y relevante para Z:  
 A. Información adicional en ( ):  
 A.1 Marcado  
 A.2 Marcado



## EU-Declaration of Conformity

**MinebeaMitsumi**  
Passion to Create Value through Difference

### cești keel (et)

Vastavusdeklaratsioon  
1. Tootemudel / tootenumber / kehüüb vaid järgmise projekti puhul:  
2. Tootja nimi ja aadress (2.1) ning tema volitatud esindaja (2.2);  
3. Käesolev vastavusdeklaratsioon on välja antud tootja ainuvastuolul.  
4. Deklareeritava toote:  
5. Üllalrijeldatud deklareeritava toode on kooskõlas asjaomaste liidu üllustamisaktidega;  
6. Viited kasutatud harmoneeritud standarditele või viited muudele tehnilistele spetsifikatsioonidele, millele vastavust deklareeritakse;  
7. Teavitatud asutus w teostas x ja andis välja teendi z, mis on asjakohane y-le:  
A. Lisateave järgmise kohta ( ):  
A.1 Märgistus  
A.2 Märgistus

### français (fr)

Déclaration de conformité  
1. Modèle / numéro de produit / valable uniquement pour le numéro de projet:  
2. Nom et adresse du fabricant (2.1) et de son mandataire (2.2);  
3. La présente déclaration de conformité est établie sous la seule responsabilité du fabricant.  
4. Objet(s) de la déclaration:  
5. Le ou les objets de la déclaration dénite eidesus est(sont) conformet(s) à la législation d'harmonisation de l'Union applicable;  
6. Références des normes harmonisées pertinentes appliquées ou des autres spécifications techniques par rapport auxquelles la conformité est déclarée;  
7. L'organisme notifié w a effectué x et a établi l'attestation y applicable à z:  
A. Informations complémentaires relatives à ( ):  
A.1 Marquage  
A.2 Marquage

### hrvatski (hr)

Izjava o sukladnosti  
1. Model proizvoda / broj proizvoda / vrijedi samo za broj projekta:  
2. Naziv i adresa proizvođača (2.1) i njegovog ovlaštenog zastupnika (2.2);  
3. Za izdavanje ove izjave o sukladnosti odgovoran je isključivo proizvođač.  
4. Predmet(i) izjave:  
5. Predmet(i) navedene izjave je(su) u skladu s njerodavnim zakonodavstvom Unije o usklađivanju;  
6. Pozivanja na relevantne priložene usklađene norme ili pozivanja na ostale tehničke specifikacije u vezi s kojima se izjavljuje sukladnost;  
7. Prijavljeno tijelo w provelo je x i izdalo certifikat y koji je relevantan za z:  
A. Dodatne informacije o proizvodu ( );  
A.1 Označavanje  
A.2 Označavanje

### magyar (hu)

Megfelelőségi nyilatkozat  
1. Termékmodell / termékszám / kizárólag az alábbi projektszámhoz érvényes:  
2. A gyártó (2.1) vagy adott esetben meghatalmazott képviselőjének (2.2) neve és címe:  
3. Ezt a megfelelőségi nyilatkozatot a gyártó kizárólagos felelőssége mellett adják ki.  
4. A nyilatkozat tárgya(i):  
5. A fent ismertetett nyilatkozat tárgya megfelel a vonatkozó uniós harmonizációs jogszabályoknak;  
6. Az alkalmazott harmonizált szabványokra való hivatkozás vagy az azokra az egyéb műszaki leírásokra való hivatkozás, amelyekkel kapcsolatban megfelelőségi nyilatkozatot tettek;  
7. A(z) w bejelentett szervezet elvégezte a(z) x eljárást, és kiállította a(z) z kapcsolódó y tanúsítványt:  
A. További információk ( ):  
A.1 Jelölés  
A.2 Jelölés

### italiano (it)

Dichiarazione di conformità  
1. Modello di prodotto / numero di prodotto / valido unicamente per numero di progetto:  
2. Nome e indirizzo del fabbricante (2.1) e del relativo rappresentante autorizzato (2.2);  
3. La presente dichiarazione di conformità è rilasciata sotto la responsabilità esclusiva del fabbricante.  
4. Oggetto/i della dichiarazione:  
5. L'oggetto o gli oggetti della dichiarazione di cui sopra sono conformi alla pertinente normativa di armonizzazione dell'Unione;  
6. Riferimento alle pertinenti norme armonizzate utilizzate o riferimenti alle altre specifiche tecniche in relazione alle quali è dichiarata la conformità;  
7. L'organismo notificato w ha effettuato x e rilasciato il certificato y pertinente a z:  
A. Informazioni aggiuntive su ( ):  
A.1 Marcatura  
A.2 Marcatura

### Latvian kalba (lv)

Atbilstības deklarācija  
1. Ģaminio modelis / ģaminio numeris / galioja tikai projekto numuriem:  
2. Ģaminiojo (2.1) ir jo ģgaliojojo atstovo (2.2) pavadnimas ir adresas:  
3. Ši atbilstības deklarācija izdoita tikai ģaminiojojo atsakomybe.  
4. Deklarācijas objekts (objekti):  
5. Pirmiau aprašytas deklarācijas objekts (objekti) atbinka susijusius derinamosius Sąjungos teisės aktus:  
6. Susijusių taisykių darninių standartų nuorodos arba kitų techninių specifikacijų, pagal laurus buvo deklaruota atbilstis, nuorodos;  
7. Notifikuotoji įstaga w atliko x ir išdavė sertifikātą y dėl z:  
A. Papildoma informacija ( ):  
A.1 Ženklinimas  
A.2 Ženklinimas



CE-00055A

## EU-Declaration of Conformity

**MinebeaMitsumi**  
Passion to Create Value through Difference

### latviešu valoda (lv)

#### Athibstības deklarācija

1. Produkta modeļa / produkta numurs / derīgs tikai projektam Nr.:
2. Ražotāja (2.1.) un tā pilnvarotā pārstāvja (2.2.) nosaukums un adrese:
3. Šī atbilstības deklarācija ir izdota vienīgi uz ražotāja atbildību.
4. Deklarācijas priekšmets vai priekšmeti:
5. Iepriekš aprakstītais deklarācijas priekšmets vai priekšmeti atbilst attiecīgajam Savienības saskaņošanas tiesību aktam:
6. Atsaucies uz attiecīgajiem izmantojamiem saskaņotajiem standartiem vai uz citām tehniskajām specifikācijām, attiecībā uz ko tiek deklarēta atbilstība:
7. Paziņotā struktūra w ir veikusi x un izsniegusi sertifikātu y, kas attiecas uz z:

- A. Papildu informācija par ( ):  
A.1. Marķējums  
A.2. Marķējums

### malta (mt)

#### Dikjarazzjoni ta' konformità

1. Modell tal-prodott / numru tal-prodott / valida biss għan-numru tal-proġett:
2. L-isem u l-indirizz tal-manifattur (2.1) u tarappreżentant awtorizzat tiegħu (2.2):
3. Din id-dikjarazzjoni ta' konformità tinfahreg taħt ir-responsabbiltà unika tal-manifattur.
4. L-għan(jiet) tad-dikjarazzjoni:
5. L-għan(jiet) tad-dikjarazzjoni deskritt(i) haqqa fuq luwa/luhma konformi mal-legislazzjoni ta' armonizzazzjoni rilevanti tal-Unjoni:
6. Ir-referenzi għall-istandards armonizzati rilevanti li ntuzaw, jew ir-referenzi għall-specifikazzjonijiet tekniċi l-oħra li skonthom qed tiġi ddiġjarata l-konformità:
7. Il-korp notifikat w wettaq x u hareġ iċertifikat y rilevanti għal z:

- A. Informazzjoni addizzjonali fuq ( ):  
A.1. Immarkar  
A.2. Immarkar

### nederlands (nl)

#### Conformiteitsverklaring

1. Productmodel / productnummer / uitsluitend geldig voor projectnummer:
2. Naam en adres van de fabrikant (2.1) en zijn gemachtigde (2.2):
3. Deze conformiteitsverklaring wordt verstrekt onder volledige verantwoordelijkheid van de fabrikant.
4. Voorwerp(en) van de verklaring:
5. Het (de) hierboven beschreven voorwerp(en) is (zijn) in overeenstemming met de desbetreffende harmonisatiewetgeving van de Unie:
6. Vermelding van de toegepaste relevante geharmoniseerde normen of van de overige technische specificaties waarop de conformiteitsverklaring betrekking heeft:
7. De aangemelde instantie w heeft een x uitgevoerd en het certificaat y verstrekt dat relevant is voor z:

- A. Aanvullende informatie over ( ):  
A.1. Markering  
A.2. Markering

### polski (pl)

#### Deklaracja zgodności

1. Model produktu / numer produktu / ważny wyłącznie dla projektu o numerze:
2. Nazwa i adres producenta (2.1) oraz jego upoważnionego przedstawiciela (2.2):
3. Niniejsza deklaracja zgodności wydana zostaje na wyłączną odpowiedzialność producenta.
4. Przedmiot(-y) deklaracji:
5. Wymagania powyżej przedmiot (lub przedmiotów) niniejszej deklaracji jest zgodny z odpowiednimi wymaganiami unijnego prawodawstwa harmonizacyjnego:
6. Odwołania do odpowiednich norm harmonizowanych, które zastosowano, lub do innych specyfikacji technicznych, w stosunku do których deklarowana jest zgodność:
7. Jednostka notyfikowana w przeprowadziła x i wydała certyfikat y i odpowiedni dla z:

- A. Informacje dodatkowe o ( ):  
A.1. Oznakowanie  
A.2. Oznakowanie

### português (pt)

#### Declaração de conformidade

1. Modelo do produto / número do produto / somente válido para o número de projeto:
2. Nome e endereço do fabricante (2.1) e do seu mandatário (2.2):
3. A presente declaração de conformidade é emitida sob a exclusiva responsabilidade do fabricante.
4. Objeto(s) da declaração:
5. O(s) objeto(s) da declaração acima descrito(s) está(ão) em conformidade com a legislação aplicável de harmonização da União:
6. Referências às normas harmonizadas aplicáveis utilizadas ou às outras especificações técnicas em relação às quais é declarada a conformidade:
7. O organismo notificado w realizou x e emitiu o certificado y relevante para z:

- A. Informações complementares relativa a ( ):  
A.1. Marcação  
A.2. Marcação

### română (ro)

#### Declarație de conformitate

1. Modelul de produs / Număr produs / valabil numai pentru numărul proiectului:
2. Denumirea și adresa producătorului (2.1) și a reprezentantului său autorizat (2.2):
3. Prezenta declarație de conformitate este emisă pe răspunderea exclusivă a producătorului.
4. Obiectul (obiectele) declarației:
5. Obiectul (obiectele) declarației descrise mai sus sunt în conformitate cu legislația relevantă de armonizare a Uniunii:
6. Trimiteri la standardele armonizate relevante folosite sau trimiteri la edelalte specificații tehnice în legătură cu care se declară conformitatea:
7. Organismul notificat w a efectuat x și a emis certificatul y corespunzător pentru z:

- A. Informații suplimentare despre ( ):  
A.1. Marcaj  
A.2. Marcaj



## EU-Declaration of Conformity

**MinebeaMitsumi**  
Passion to Create Value through Difference

### slovenčina (sk)

Vyhlasenie o zhode  
1. Model výrobku / číslo výrobku / platné len pre číslo projektu:  
2. Meno/názov a adresa výrobcu (2.1) a jeho splnomocneného zástupcu (2.2):  
3. Toto vyhlásenie o zhode sa vydáva na vlastnú zodpovednosť výrobcu.  
4. Predmet(-y) vyhlásenia:  
5. Uvedený predmet si uvedené predmety vyhlásenia sú v zhode s príslušnými harmonizačnými právnymi predpismi Únie:  
6. Odkazy na príslušné použité harmonizované normy alebo odkazy na iné technické špecifikácie, v súvislosti s ktorými sa zhoda vyhlasuje:  
7. Notifikovaný orgán v vykonal x a vydal certifikát y relevantný pre z:  
A. Doplňujúce informácie o ( ):  
A.1 Označenie  
A.2 Označenie

### slovenščina (sl)

Izjava o skladnosti  
1. Model proizvoda / serijska številka proizvoda / veljavno samo za številko projekta:  
2. Ime in naslov proizvajalca (2.1) ter njegovega pooblaščenega zastopnika (2.2):  
3. Za izdajo te izjave o skladnosti je odgovoren izključno proizvajalec.  
4. Predmet(i) izjave:  
5. Predmet(i) navedene izjave je (so) v skladu z ustrežno zakonodajo Unije o harmonizaciji:  
6. Sklicevanja na uporabljene ustrezne harmonizirane standarde ali sklicevanja na druge tehnične specifikacije v zvezi s skladnostjo, ki je navedena v izjavi:  
7. Priglašeni organ w je izvedel x in izdal certifikat y, pomemben za z:  
A. Dodatne informacije o ( ):  
A.1 Oznaka  
A.2 Oznaka

### suomi (fi)

Vaatumustenmukaisuusvakuutus  
1. Tuotemalli / tuotenumero / koskee vain projektinumeroa:  
2. Valmistajan (2.1) ja valtuutetun edustajan (2.2) nimi ja osoite:  
3. Tämä vaatimustenmukaisuusvakuutus on annettu valmistajan yksinomaisella vastuulla.  
4. Vakuutuksen kohde (kohdet):  
5. Edellä kuvattu (kuvattu) vakuutuksen kohde (kohdet) on (ovat) asiaa koskevan unionin yhdenmukaistamislainsäädännön vaatimusten mukainen (mukaisia):  
6. Viittaus niihin asiaan koskeviin yhdenmukaistettuihin standardeihin, joita on läydetty, tai viittaus muihin tekniisin eritelmiin, joiden perusteella vaatimustenmukaisuusvakuutus on annettu:  
7. Ilmoitettu laitos w suoritti x ja antoi todistuksen y liityen z:  
A. Lisä tietoja ( ):  
A.1 Merkintä  
A.2 Merkintä

### svenska (sv)

Försäkran om överensstämmelse  
1. Produktmodell / produktnummer / gäller endast för projektnummer:  
2. Tillverkarens namn och adress (2.1) och dess auktoriserade representant (2.2):  
3. Denna försäkran om överensstämmelse utfärdas på tillverkarens eget ansvar.  
4. Föremål för försäkran:  
5. Föremålet/föremålen för försäkran ovan överensstämmer med den relevanta harmoniserade unionslagstiftningen:  
6. Hänvisningar till de relevanta harmoniserade standarder som använts eller hänvisningar till de andra tekniska specifikationer enligt vilka överensstämmelsen försäkras:  
7. Det anmälda organet w har utfört x och utfärdat intyget y relevant för z:  
A. Ytterligare information om ( ):  
A.1 Märkning  
A.2 Märkning

9.2 17-124




Certificate Number: 17-124  
Page 1 of 3

**NATIONAL TYPE EVALUATION PROGRAM**

# Certificate of Conformance

for Weighing and Measuring Devices


<p><b>For:</b>                  Load Cell                  Bending Beam                  Model: MI 10, MI 10T, PR79 &amp; PR79T Series  <math>m_{max}</math>: 3500 and 5000 (see table Page 2), Class III, Single Cell                  5000 (see table Page 2), Class III, Multiple Cell                  10 000, Class III, Multiple Cell                  Capacity: 91 kg to 5099 kg                  Accuracy Class: III/III</p>	<p><b>Submitted By:</b>                  MinebeaMitsumi Inc.                  1-1-1, Katase                  Fujisawa, Kanagawa 251-8531                  Japan                  Tel: +81 (0) 466 22 7152                  Fax: +81 (0) 466 22 1701                  Contact: Mr. Katsumi Shibasaki                  Email: <a href="mailto:kshibasaki@minebeamitsumi.com">kshibasaki@minebeamitsumi.com</a>                  Web site: <a href="http://www.minebea-med.com">www.minebea-med.com</a></p>
--	--

**Standard Features and Options**

- The specific load cell models, capacities and  $v_{min}$  values covered by this Certificate are listed in the table on Page 2.
- Nominal output: 2.0 mV/V
- Stainless Steel
- 6 Wire Design
- Minimum Dead Load: 0 kg

Temperature Range: -10 °C to 40 °C (14 °F to 104 °F)

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of "NIST Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages.



James Cassidy  
Chairman, NCWM, Inc.



Kristin Macey  
Chairman, National Type Evaluation Program Committee  
Issued: November 2, 2017

1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.



Certificate Number: 17-124  
Page 2 of 3

MinebeaMitsumi Inc.

Load Cell / M110, M110T, PR79 & PR79T Series

**Application:** The load cells may be used in Class III scales for single cell applications and Class III and III L for multiple cell applications consistent with the model designations, number of scale divisions, and parameters specified in this certificate. Load cells of a given accuracy class may be used in applications with lower accuracy class requirements provided the number of scale divisions, the  $v_{min}$  value, and temperature range are suitable for the application. The manufacturer may market the load cell with fewer divisions ( $n_{max}$ ) and with greater  $v_{min}$  values than those listed on the certificate. However, the load cells must be marked with the appropriate  $n_{max}$  and  $v_{min}$  for which the load cell may be used.

**Specific Capacities and  $v_{min}$  Values:**

Models	Capacity	$v_{min}$ Class III Single Cell, $n_{max} = 5000$ (except 227 kg & 454 kg / $n_{max} = 3500$ )	$v_{min}$ Class III Multiple Cell, $n_{max} = 5000$	$v_{min}$ Class III L Multiple Cell, $n_{max} = 10\ 000$
M110, M110T, PR79 and PR79T Series	91 kg*	4.6 g	4.6 g	1.5 g
	227 kg*	13 g	13g	4.2 g
	454 kg	25 g	25 g	8.4 g
* load cell tested	1134 kg*	57 g	57 g	19 g
	1760 kg	88 g	88 g	29 g
	2268 kg	113 g	113 g	38 g
	5099 kg	255 g	255 g	85 g

**Identification:** A pressure sensitive identification label located on the cell, states manufacturer name, model, serial number and rated capacity. Other pertinent information will be specified on the Calibration Certificate accompanying the cell.

**Test Conditions:** This certificate is issued based upon the following tests and upon information provided by the manufacturer. A 91 kg, 227 kg and 1134 kg capacity load cell were tested by the NMI Certain B.V. at The Netherlands facility. Testing was conducted in accordance with the OIML DoMC Mutual Acceptance Arrangement, signed by the NCWM as a utilizing participant for load cell testing. Testing was conducted using deadweights as the reference standard. The load cells were tested over a temperature range of -10 °C to 40 °C with tests run on each cell at each temperature. The temperature effect on zero was measured and a time dependence (creep) test was performed. The barometric pressure test to determine sensitivity of the load cell design to changes in barometric pressure was conducted. The data were analyzed for single and multiple load cell applications. OIML R60 selection criteria were used to determine cells tested.

**Evaluated By:** S.J. Koeman, M.M.J. Meijer (NMI)

**Type Evaluation Criteria Used:** NIST, Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices, 2017. NCWM, Publication 14: Weighing Devices, 2017.

**Conclusion:** The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

**Information Reviewed By:** J. Truex (NCWM)



Certificate Number: 17-124  
Page 3 of 3

MinebeaMitsumi Inc.

Load Cell / M110, M110T, PR79 & PR79T Series

Examples of Device:



## 9.3 10101



10B Airline Drive  
Albany, New York 12235  
800-554-4501  
www.agriculture.ny.gov

***Certificate of Approval***  
for Weighing and Measuring Devices

**New York State Certificate Number: 10101**  
**Effective Date: April 27, 2018**

**NTEP Certificate of Conformance Number: 17-124**

**For:**

Load Cell  
Bending Beam  
Model: M110, M110T, PR79 & PR79T Series  
 $F_{max}$ : 3500 and 5000 (see table Page 2), Class III, Single Cell  
5000 (see table Page 2), Class III, Multiple Cell  
10 000, Class III, Multiple Cell  
Capacity: 91 kg to 5099 kg  
Accuracy Class: III/IIIL

**Submitted By:**

MinebeaMitsumi Inc.  
1-1-1, Katase  
Fujisawa, Kanagawa 251-8531  
Japan  
Tel: +81 (0) 466 22 7152  
Fax: +81 (0) 466 22 1701  
Contact: Mr. Katsumi Shibasaki  
Email: [kshibasaki@minebeamitsumi.com](mailto:kshibasaki@minebeamitsumi.com)  
Web site: [www.minebea-mcd.com](http://www.minebea-mcd.com)

This certifies that the items specified in the above National Type Evaluation Program (NTEP) Certificate of Conformance are hereby approved for sale or use in the State of New York.





The NTEP Certificate of Conformance, as issued by the National Conference on Weights and Measures, is accepted under the terms of INYCRR Part 220.1. Evaluation results and device characteristics necessary for inspection and use in commerce are stated in the NTEP Certificate of Conformance. Copies of the NTEP Certificate of Conformance are available on request and are available for inspection at the Bureau's Metrology Office at 6 Harriman Campus Road, Albany, NY 12206.

Michael Sikula, Director  
NYS Bureau of Weights and Measures

WM-23 (rev. 02/15) Duplicate Original

NTEP

## 9.4 R60/2000-NL1-17.55

	<h2 style="text-align: center;">OIML Certificate of Conformity</h2>
<b>OIML Member State</b> The Netherlands	Number R60/2000-NL1-17.55 Project number 1900957 Page 1 of 2
Issuing authority	NMI Certin B.V. Person responsible: C. Oosterman
Applicant and Manufacturer	MinebeaMitsumi Inc. 1-1-1, Katase Fujisawa-shi, Kanagawa-ken 251-8531 Japan
Identification of the certified type	A <b>bending beam load cell</b> , with strain gauges. Type : M110 or PR79 M110T or PR79T
Characteristics	See next page
<p>This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):</p>	
<b>OIML R60</b> - Edition 2000 (E) for accuracy class C	
<p>This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.</p>	
<p><i>Important note:</i> Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.</p>	
Issuing Authority	<b>NMI Certin B.V., OIML Issuing Authority NL1</b> 4 September 2017
 C. Oosterman Head Certification Board	
NMI Certin B.V. Hugo de Grootplein 1 3314 EG Dordrecht the Netherlands T +31 78 6332332 certin@nmi.nl www.nmi.nl	<p>This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.</p> <p>The notification of NMI Certin B.V. as Issuing Authority can be verified at <a href="http://www.oiml.org">www.oiml.org</a></p>
 	



# OIML Certificate of Conformity

**OIML Member State**  
The Netherlands

Number R60/2000-NL1-17.55  
Project number 1900957  
Page 2 of 2

The conformity was established by the results of tests and examinations provided in the associated OIML Test Reports:

- No. NMI-1900957-01 dated 18 August 2017 that includes 97 pages;
- No. NMI-1900957-02 dated 18 August 2017 that includes 90 pages;
- No. NMI-1900957-03 dated 18 August 2017 that includes 90 pages.

### Characteristics of the load cell:

Maximum capacity ( $E_{max}$ )	91 kg up to 227 kg	227 kg up to 1134 kg	1134 kg up to and including 5099 kg
Minimum dead load	0 kg		
Accuracy Class	C		
Rated Output	2,0 mV/V		
Maximum number of load cell intervals (n) <sup>(1)</sup>	3000		
Ratio of minimum LC Verification interval <sup>(1)</sup> $Y = E_{max} / v_{min}$	20000	18000	20000
Ratio of minimum dead load output return <sup>(1)</sup> $Z = E_{max} / (2 * DR)$	3000		
Input impedance	1100 $\Omega \pm 10 \Omega$		
Temperature range	-10 °C / + 40 °C		
Fraction $p_{LC}$	0,7		
Humidity Class	CH		
Safe overload	150 % of $E_{max}$		
Output impedance	1000 $\Omega \pm 1 \Omega$		
Recommended excitation	10 V AC / DC		
Excitation maximum	15 V AC / DC		
Transducer material	Stainless steel		
Atmospheric protection	Hermetically welded		

### Remark:




1. The characteristics for  $n_{max}$ , Y and Z can be reduced separately.

Each produced load cell is provided with an accompanying document with information about its characteristics.

The above identified Type (represented by the sample(s) identified in the OIML Test Report) have been found to comply with the additional national requirements established by the United States of America (NIST Handbook 44 and NCWM Publication 14), included in the MAA Declaration of Mutual Confidence:

- R 60 DoMC-01 rev.0, Additional requirements from the United States;
- R 60 DoMC-02 rev.0, Additional requirements from the United States.

## 9.5 TC11073

	<b>Test Certificate Parts Certificate</b>						
	Number <b>TC11073</b> revision 0 Project number 1900957 Page 1 of 1						
Issued by	NMI Certin B.V.						
In accordance with	WELMEC 8.8 Issue 2, WELMEC 2.4 Issue 2, OIML R 60 (2000), EN 45501:2015.						
Producer	MinebeaMitsumi Inc. 1-1-1, Katase Fujisawa-shi, Kanagawa-ken 251-8531 Japan						
Measuring instrument	A <b>bending beam load cell</b> , with strain gauges, tested as a part of a weighing instrument.						
	<table border="0"> <tr> <td>Brand</td> <td>:</td> <td>Minebea or Minebea intec</td> </tr> <tr> <td>Designation</td> <td>:</td> <td>M110 or PR79 M110T or PR79T</td> </tr> </table>	Brand	:	Minebea or Minebea intec	Designation	:	M110 or PR79 M110T or PR79T
Brand	:	Minebea or Minebea intec					
Designation	:	M110 or PR79 M110T or PR79T					
	<p>Further properties are described in the annexes:</p> <ul style="list-style-type: none"> <li>- Description TC11073 revision 0;</li> <li>- Documentation folder TC11073-1.</li> </ul>						
	<p>An overview of performed tests is given in the annex:</p> <ul style="list-style-type: none"> <li>- Description TC11073 revision 0.</li> </ul>						
Issuing Authority	<p><b>NMI Certin B.V.</b> 4 September 2017</p>  <p>C. Gosterman Head Certification Board</p>						
<p><b>NMI Certin B.V.</b> Hugo de Grootplein 1 3314 EG Dordrecht The Netherlands T +31 78 6332332 certin@nmi.nl www.nmi.nl</p>	<p>This document is issued under the provision that no liability is accepted and that the producer shall indemnify third-party liability.      Reproduction of the complete document only is permitted</p>						
	 <p><b>INSPECTION</b> RvA 1122</p>						



## Description

Number **TC11073** revision 0  
Project number 1900957  
Page 1 of 2

### 1 General information about the load cell

All properties of the load cell, whether mentioned or not, shall not be in conflict with the standards mentioned in this certificate.

This certificate is the positive result of the applied voluntary, modular approach, for a component of a measuring instrument, as described in WELMEC 8.8. The complete measuring system must be covered by an EC type-approval certificate, an EC-type examination certificate or an EU-type examination certificate.

#### 1.1 Essential parts

Number	Pages	Description	Remark
11073/0-01	2	M110 or PR79 outline drawing	Mechanical / electrical
11073/0-02	2	M110T or PR79T outline drawing	Mechanical / electrical

Cable:

- The load cell is provided with a 6-wire system (=“Remote-sensing”):
- The cable length is not limited.

The cable shall be a shielded cable, the shield is not connected to the load cell.

#### 1.2 Essential characteristics

Maximum capacity ( $E_{max}$ )	91 kg up to 227 kg	227 kg up to 1134 kg	1134 kg up to and including 5099 kg
Minimum dead load	0 kg		
Accuracy Class	C		
Rated Output	2,0 mV/V		
Maximum number of load cell intervals (n)	3000		
Ratio of minimum LC Verification interval $Y = E_{max} / V_{min}$	20000	18000	20000
Ratio of minimum dead load output return $Z = E_{max} / (2 * DR)$	3000		
Input impedance	1100 $\Omega \pm 10 \Omega$		
Temperature range	-10 °C / + 40 °C		
Fraction $p_{LC}$	0,7		
Humidity Class	CH		
Safe overload	150 % of $E_{max}$		
Output impedance	1000 $\Omega \pm 1 \Omega$		



## Description

Number **TC11073** revision 0  
Project number 1900957  
Page 2 of 2

Recommended excitation	10 V AC / DC
Excitation maximum	15 V AC / DC
Transducer material	Stainless steel
Atmospheric protection	Hermetically welded

The characteristics for  $n_{max}$  and Y can be reduced separately.

Each produced load cell is provided with an accompanying document with information about its characteristics.

### 1.3 Essential shapes

Number	Pages	Description	Remark
11073/0-01	2	M110 or PR79 outline drawing	Mechanical / electrical
11073/0-02	2	M110T or PR79T outline drawing	Mechanical / electrical

The descriptive markings plate is secured against removal by sealing or will be destroyed when removed and contains at least the information and markings as described in OIML R 60 (2000) and:

- This certificate number TC11073 (in the countries where it is mandatory);
- Producers name or mark.

### 2 Seals

The connecting cable of the load cell or the junction box is provided with possibility to seal.

### 3 Conditions for conformity assessment

The compatibility of load cells and indicator is established by the manufacturer by means of the compatibility of modules form, contained in WELMEC 2, 2015 clause 10, at the time of putting into use.

Other parties may use this certificate without the written permission of the producer (WELMEC 8.8).


### 4 Reports

An overview of performed tests is given in the reports:

- No. NMI-1900957-01 dated 18 August 2017 that includes 97 pages;
- No. NMI-1900957-02 dated 18 August 2017 that includes 90 pages;
- No. NMI-1900957-03 dated 18 August 2017 that includes 90 pages.

A report can be a test report, an evaluation report, a type evaluation report and/or a pattern evaluation report.

9.6 BVS 21 ATEX E 023X



1 **EU-Baumusterprüfbescheinigung**

2 **Geräte zur bestimmungsgemäßen Verwendung in explosionsgefährdeten Bereichen  
Richtlinie 2014/34/EU**

3 Nr. der EU-Baumusterprüfbescheinigung: **BVS 21 ATEX E 023 X**

4 Produkt: **Wägezellen Typ M\*\*\*\*.\*\*\*\*\* alternativ Typ PR \*\*.\*\*\*\*\***

5 Hersteller: **Minebea Mitsumi Inc.**

6 Anschrift: **1-1-1 Katase Fujisawa, Kanagawa, Japan**

7 Die Bauart dieses Produktes sowie die verschiedenen zulässigen Ausführungen sind in der Anlage zu dieser Baumusterprüfbescheinigung festgelegt.

8 Die Zertifizierungsstelle der DEKRA Testing and Certification GmbH, benannte Stelle Nr. 0158 gemäß Artikel 17 der Richtlinie 2014/34/EU des Europäischen Parlaments und des Rates vom 26. Februar 2014, bescheinigt, dass das Produkt die wesentlichen Gesundheits- und Sicherheitsanforderungen für die Konzeption und den Bau von Produkten zur bestimmungsgemäßen Verwendung in explosionsgefährdeten Bereichen gemäß Anhang II der Richtlinie erfüllt. Die Ergebnisse der Prüfung sind in dem vertraulichen Prüfprotokoll BVS PP 21.2035 EU niedergelegt.

9 Die wesentlichen Gesundheits- und Sicherheitsanforderungen werden erfüllt unter Berücksichtigung von:



<b>EN IEC 60079-0:2018</b>	<b>Allgemeine Anforderungen</b>
<b>EN IEC 60079-7:2015 + A1:2018</b>	<b>Erhöhte Sicherheit „e“</b>
<b>EN 60079-11:2012</b>	<b>Eigensicherheit „i“</b>
<b>EN 60079-31:2014</b>	<b>Schutz durch Gehäuse „t“</b>

mit Ausnahme der Anforderungen, die in Abschnitt 18 der Anlage aufgeführt werden.


10 Falls das Zeichen „X“ hinter der Bescheinigungsnummer steht, wird in der Anlage zu dieser Bescheinigung auf besondere Bedingungen für die sichere Anwendung des Produktes hingewiesen.


11 Diese EU-Baumusterprüfbescheinigung bezieht sich nur auf den Entwurf und Bau der beschriebenen Produkte.  
Für den Herstellungsprozess und die Abgabe der Produkte sind weitere Anforderungen der Richtlinie zu erfüllen, die nicht durch diese Bescheinigung abgedeckt sind.

12 Die Kennzeichnung des Produktes muss die folgenden Angaben enthalten:

	II 1G Ex ia IIC T6/T4 Ga	M****.***** 0 *** alternativ
	II 1D Ex ia IIIC T <sub>200</sub> 165°C Da	PR **.***** E
	II 3G Ex ec IIC T6/T4 Gc	M****.***** 2 *** alternativ
	II 2D Ex tb IIIC T110°C Db	PR **.*****

DEKRA Testing and Certification GmbH  
Bochum, 07.06.2021

  
 \_\_\_\_\_  
 Geschäftsführer



Seite 1 von 4 zu BVS 21 ATEX E 023 X – Jobnumber 341428900  
Dieses Zertifikat darf nur vollständig und unverändert weiterverbreitet werden.

DEKRA Testing and Certification GmbH, Handwerkstraße 15, 70565 Stuttgart  
Zertifizierungsstelle: Dinnendahlstraße 9, 44809 Bochum  
Telefon +49 234.3696-400, Fax +49.234.3696-401, DTC-Certification-body@dekra.com

DEKRA

13 **Anlage zur**

14 **EU-Baumusterprüfbescheinigung**

**BVS 21 ATEX E 023 X**

15 **Beschreibung des Produktes**

15.1 **Gegenstand und Typ**

Wägezellen Typ M\*\*\*-\*\*\*\* \* \* \* \*

Stern	Bedeutung
1+2	Typ der Wägezelle M010, M020, M030, M040, M050, M060, M070, M080, M090, M100, M110, M130
3-6	Kapazität der Wägezelle in kg (Abhängig vom jeweiligen Typ)
	0005    5 kg
	07.5    7,5 kg
	5099    5099 kg
7	Genauigkeit (nicht Ex-relevant)
8	Ex Schutz
	0        Einsatz in Zone 0 und 20
	2        Einsatz in Zone 2 und 21
9+10	Länge der fest angeschlossenen Leitung in Meter (Abhängig vom jeweiligen Typ)
11	Nicht Ex-relevant

Alternativ Typ PR \*\*-\*\*\*\* \* \* \* \*

Stern	Bedeutung
1+2	Typ der Wägezelle PR 40, PR 43, PR 54, PR 44, PR 57, PR 47, PR 53, PR 55, PR 58, PR 77, PR 79, PR 78
3-6	Kapazität der Wägezelle (Abhängig vom jeweiligen Typ)
	0005    5 kg
	07.5    7,5 kg
	5099    5099 kg
7-8	Einheit der Kapazität [kg] oder [t]
9	Ex Schutz
	E        Einsatz in Zone 0 und 20
	ohne    Einsatz in Zone 2 und 21

Seite 2 von 4 zu BVS 21 ATEX E 023 X – Jobnumber 341428900  
 Dieses Zertifikat darf nur vollständig und unverändert weiterverbreitet werden.

DEKRA Testing and Certification GmbH, Handwerkstraße 15, 70565 Stuttgart  
 Zertifizierungsstelle: Dinnendahlstraße 9, 44809 Bochum  
 Telefon +49.234.3696-400, Fax +49.234.3696-401, DTC-Certification-body@dekra.com



**15.2 Beschreibung**  
 Die Wägezellen Typ M\*\*\*-\*\*\*\* \* 0 \*\* \* alternativ Typ PR \*\*-\*\*\*\* \*\* 0 sind für den Einsatz in Zone 0 und Zone 20 (EPL Ga und Da) in der Zündschutzart Eigensicherheit „i“ ausgeführt. Die Wägezellen Typ M\*\*\*-\*\*\*\* \* 2 \*\* \* alternativ Typ PR \*\*-\*\*\*\* \*\* 2 sind für den Einsatz in Zone 2 und Zone 21 (EPL Gc und Db) in den Zündschutzarten Erhöhte Sicherheit „ec“ und Schutz durch Gehäuse „tb“ ausgeführt.

Die Wägezellen bestehen aus einem massiven Metallblock, welcher mit Dehnungsmessstreifen versehen ist. Abhängig vom jeweiligen Typ werden die Dehnungsmessstreifen entweder komplett vergossen oder der Raum wird mit einem Metallstopfen gasdicht verschweißt.

Das Metallgehäuse der Typen M010, PR 40, M020, PR 43, M040, PR 44, M060 und PR 47 besteht aus Aluminium.

Das Metallgehäuse der Typen M030, PR 54, M050, PR 57, M070, PR 53, M080, PR 55, M090, PR 58, M100, PR 77, M110, PR 79, M130 und PR 78 besteht aus Chrom-Nickel-Stahl.

Der Anschluss erfolgt über die fest angeschlossenen Leitungen, die direkt in den vergossenen oder verschweißten Raum führen. Die Farbe des Leitungsmantels ist immer grün. Bei den eigensicheren Typen wird zur Kennzeichnung ein blauer Schrumpfschlauch verwendet. Die Einführung erfolgt über eine eigenproduzierte Kabel- und Leitungseinführung die auch Gegenstand dieser Baumusterprüfung ist.

**Auflistung aller verwendeten Komponenten mit älterem Normenstand**

Keine

**15.3 Kenngrößen**

Nicht eigensichere Kenngrößen (Typ M\*\*\*-\*\*\*\* \* 2 \*\* \* / PR \*\*-\*\*\*\* \*\*)

Bemessungsspannung		30	VDC
Bemessungsstrom		500	mA
Bemessungsleistung		3,1	W

Eigensichere Kenngrößen (Typ M\*\*\*-\*\*\*\* \* 0 \*\* \* / PR \*\*-\*\*\*\* \*\* E)

Maximale Eingangsspannung	U <sub>i</sub>	30	VDC
Maximaler Eingangsstrom	I <sub>i</sub>	500	mA
Maximale Eingangsleistung	P <sub>i</sub>	1,8	W für T6 (Typ PR53)
		1,95	W für T6 (alle anderen Typen)
		4	W für T4 (alle Typen)

Die Wägezellen enthalten keine konzentrierten Kapazitäten oder Induktivitäten.

Maximale innere Kapazität	C <sub>i</sub>	130	pF / m
Maximale innere Induktivität	L <sub>i</sub>	0,95	µH / m

**Thermische Kenngrößen**


Umgebungstemperaturbereich / Temperaturklasse / Oberflächentemperatur  
 -30 °C ≤ T<sub>amb</sub> ≤ 40 °C (T6)  
 -30 °C ≤ T<sub>amb</sub> ≤ 70 °C (T4 und Staub)

**16 Prüfprotokoll**

BVS PP 21.2035 EU, Stand 07.06.2021



Seite 3 von 4 zu BVS 21 ATEX E 023 X – Jobnumber 341428900  
 Dieses Zertifikat darf nur vollständig und unverändert weiterverbreitet werden.  
 DEKRA Testing and Certification GmbH, Handwerkstraße 15, 70565 Stuttgart  
 Zertifizierungsstelle: Dinnendahlstraße 9, 44809 Bochum  
 Telefon +49.234.3696-400, Fax +49.234.3696-401, DTC-Certification-body@dekra.com



17 **Besondere Bedingungen für die Verwendung**

17.1.1 Das Gerät ist für einen Umgebungstemperaturbereich von -30 °C bis 40 °C in der Temperaturklasse T6 und einem Umgebungstemperaturbereich von -30 °C bis 70 °C in der Temperaturklasse T4 oder für Staubanwendungen geeignet

17.1.2 Für den Einsatz in EPL Ga müssen die Geräte so installiert werden, dass Zündgefahren durch Schlag- oder Reibungsfunken ausgeschlossen werden können.

17.1.3 Die Kabelverschraubungen wurden mit einer reduzierten Zugkraft gemäß Abschnitt A.3.1 der EN IEC 60079-0 geprüft und dürfen nur mit fester Installation verwendet werden. Der Anwender hat für eine ausreichende Befestigung des Kabels zu sorgen.

17.1.4 Hohe oder wiederkehrende Aufladungsprozesse müssen für den Einsatz in EPL Ga ausgeschlossen werden.

17.1.5 Die nichtmetallischen Oberflächen der Wägezellen müssen durch die Installation vor mechanischen Gefährdungen geschützt werden.

18 **Wesentliche Gesundheits- und Sicherheitsanforderungen**


Die wesentlichen Gesundheits- und Sicherheitsanforderungen sind durch die unter Abschnitt 9 gelisteten Normen abgedeckt.  
In Ergänzung zu den wesentlichen Gesundheits- und Sicherheitsanforderungen, die durch die unter Abschnitt 9 gelisteten Normen abgedeckt werden, wurden folgende Anforderungen betrachtet und die Übereinstimmung in dem Prüfbericht nachgewiesen:

Die im Anhang verwendete Norm IEC 60079-7:2015 Ed. 5.1 ist technisch gleichwertig zu der auf der 1. Seite aufgelisteten EN IEC Norm.  
Die im Anhang verwendete Norm IEC 60079-0:2017 Ed. 7 ist technisch gleichwertig zu der auf der 1. Seiten aufgelisteten EN IEC-Norm. Für dieses Produkt ist die Norm sicherheitstechnisch gleichwertig zur harmonisierten Norm EN IEC 60079-0:2018. Die Kennzeichnung entspricht der Richtlinie 2014/34/EU (siehe Abschnitt 5 dieses Prüfprotokolls).


19 **Zeichnungen und Unterlagen**

Die Zeichnungen und Unterlagen sind in dem vertraulichen Prüfprotokoll gelistet.

Seite 4 von 4 zu BVS 21 ATEX E 023 X – Jobnumber 341428900  
Dieses Zertifikat darf nur vollständig und unverändert weiterverbreitet werden.

 Dakks  
Deutscher  
Zertifizierungsrat  
D 20 171343 00

DEKRA Testing and Certification GmbH, Handwerkstraße 15, 70565 Stuttgart  
Zertifizierungsstelle: Dinnendahlstraße 9, 44809 Bochum  
Telefon +49.234.3696-400, Fax +49.234.3696-401, DTC-Certification-body@dekra.com



**Translation**

**1 EU-Type Examination Certificate**

**2 Equipment intended for use in potentially explosive atmospheres Directive 2014/34/EU**

**3 EU-Type Examination Certificate Number: BVS 21 ATEX E 023 X**

**4 Product: Load cell type M\*\*\*.\*\*\*\* \* \* \* \* alternatively type PR \*\*.\*\*\*\* \* \* \***

**5 Manufacturer: Minebea Mitsumi Inc.**

**6 Address: 1-1-1 Katase Fujisawa, Kanagawa, Japan**

**7** This product and any acceptable variations thereto are specified in the appendix to this certificate and the documents referred to therein.

**8** DEKRA Testing and Certification GmbH, Notified Body number 0158, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
The examination and test results are recorded in the confidential Report No. BVS PP 21.2035 EU.

**9** The Essential Health and Safety Requirements are assured in consideration of:



<b>EN IEC 60079-0:2018</b>	<b>General requirements</b>
<b>EN IEC 60079-7:2015 + A1:2018</b>	<b>Increased Safety "e"</b>
<b>EN 60079-11:2012</b>	<b>Intrinsic Safety "i"</b>
<b>EN 60079-31:2014</b>	<b>Protection by Enclosure "t"</b>

Except in respect of those requirements listed under item 18 of the appendix.

**10** If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Special Conditions for Use specified in the appendix to this certificate.

**11** This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.


**12** The marking of the product shall include the following:


	II 1G Ex ia IIC T6/T4 Ga	M***.**** * 0 * * * * alternatively
	II 1D Ex ia IIIC T <sub>200</sub> 165°C Da	PR **.**** * * E
	II 3G Ex ec IIC T6/T4 Gc	M***.**** * 2 * * * * alternatively
	II 2D Ex tb IIIC T110°C Db	PR **.**** * *

DEKRA Testing and Certification GmbH  
Bochum, 2021-06-07

Signed: Jörg-Timm Kilisch  
\_\_\_\_\_  
Managing Director

Page 1 of 4 of BVS 21 ATEX E 023 X – Jobnumber 341428900  
This certificate may only be reproduced in its entirety and without any change.

 DEKRA Testing and Certification GmbH, Handwerksstr. 15, 70565 Stuttgart, Germany  
Certification body: Dinnendahlstr. 9, 44809 Bochum, Germany  
Phone +49.234.3696-400, Fax +49.234.3696-401, e-mail DTC-Certification-body@dekra.com



13 **Appendix**

14 **EU-Type Examination Certificate**

**BVS 21 ATEX E 023 X**

15 **Product description**

15.1 **Subject and type**

Load cell type M\*\*\*-\*\*\*\*\*

Asterisk	Description
1+2	Type of load cell M010, M020, M030, M040, M050, M060, M070, M080, M090, M100, M110, M130
3-6	Capacity of the load cell in kg (depending on the type) 0005    5 kg 07.5    7.5 kg 5099    5099 kg
7	Accuracy (not Ex-relevant)
8	Ex protection 0        Useable in Zone 0 and 20 2        Useable in Zone 2 and 21
9+10	Length of the permanently attached supply line in meter (depending on the type)
11	Not Ex-relevant

Alternatively type PR \*\*-\*\*\*\*\*

Asterisk	Description
1+2	Type of load cell PR 40, PR 43, PR 54, PR 44, PR 57, PR 47, PR 53, PR 55, PR 58, PR 77, PR 79, PR 78
3-6	Capacity of the load cell (depending on the type)
7-8	Unit of the capacity value [kg] or [t]
9	Ex protection E        Useable in Zone 0 and 20 w/o     Useable in Zone 2 and 21

Page 2 of 4 of BVS 21 ATEX E 023 X – Jobnumber 341428900  
 This certificate may only be reproduced in its entirety and without any change.

DEKRA Testing and Certification GmbH, Handwerkstr. 15, 70565 Stuttgart, Germany  
 Certification body: Dinnendahlstr. 9, 44809 Bochum, Germany  
 Phone +49.234.3696-400, Fax +49.234.3696-401, e-mail DTC-Certification-body@dekra.com



**15.2 Description**

The load cells type M\*\*\*.\*\*\* \* 0 \*\*\* alternatively type PR \*\*.\*\*\* \*\* 0 are designed for use in zone 0 and zone 20 (EPL Ga and Da) in the type of protection intrinsic safety "i". The load cells type M\*\*\*.\*\*\* \* 2 \*\*\* alternatively type PR \*\*.\*\*\* \*\* 2 are designed for use in zone 2 and zone 21 (EPL Gc and Db) in the type of protection increased safety "ec" and protection by enclosure "tb".

The load cells consist of a solid metal block, which is provided with strain gauges. Depending on the type, the strain gauges are either completely encapsulated or the space is welded gas-tight with a metal plug.

The metal housing of types M010, PR 40, M020, PR 43, M040, PR 44, M060 and PR 47 is made of aluminium.

The metal housing of types M030, PR 54, M050, PR 57, M070, PR 53, M080, PR 55, M090, PR 58, M100, PR 77, M110, PR 79, M130 and PR 78 is made of chrome-nickel steel.

The connection is made through the fixed conductors, which lead directly into the potted or welded compartment. The colour of the cable sheath is always green. In the case of intrinsically safe types, a blue heat-shrinkable sleeve is used for identification. The entry is made via an own-produced cable gland for cables and conductors, which is also the subject of this type test.

**Listing of all components used referring to older standards**

None

**15.3 Parameters**

Non-intrinsically safe parameters (type M\*\*\*.\*\*\* \* 2 \*\*\* / PR \*\*.\*\*\* \*\*)

Rated voltage		30	VDC
Rated current		500	mA
Rated power		3.1	W

Intrinsically safe parameters (type M\*\*\*.\*\*\* \* 0 \*\*\* / PR \*\*.\*\*\* \*\* E)

Maximum input voltage	U <sub>i</sub>	30	VDC
Maximum input current	I <sub>i</sub>	500	mA
Maximum input power	P <sub>i</sub>	1.8	W for T6 (type PR53)
		1.95	W for T6 (all other types)
		4	W for T4 (all types)
The load cells do not contain any concentrated capacitances or inductances.			
Maximum internal capacitance	C <sub>i</sub>	130	pF / m
Maximum internal inductance	L <sub>i</sub>	0,95	µH / m

Thermal parameters

Ambient temperature range / Temperature class / Surface temperature

-30 °C ≤ T<sub>amb</sub> ≤ 40 °C (T6)  
 -30 °C ≤ T<sub>amb</sub> ≤ 70 °C (T4 and dust)

**16 Report Number**

BVS PP 21.2035 EU, as of 2021-06-07

**17 Special Conditions for Use**

17.1 The equipment is suitable for an ambient temperature range from -30 °C up to 40 °C for temperature class T6 and an ambient temperature range from -30 °C up to 70 °C for temperature class T4 or dust applications.

17.2 The equipment has to be installed in such a way that any ignition hazards caused by impact or friction can be excluded for use in EPL Ga.

Page 3 of 4 of BVS 21 ATEX E 023 X – Jobnumber 341428900  
 This certificate may only be reproduced in its entirety and without any change.



DEKRA Testing and Certification GmbH, Handwerksstr. 15, 70565 Stuttgart, Germany  
 Certification body: Dinnendahlstr. 9, 44809 Bochum, Germany  
 Phone +49.234.3696-400, Fax +49.234.3696-401, e-mail DTC-Certification-body@dekra.com



- 17.3 The cable glands have been tested with a reduced tensile force according to section A.3.1 of EN IEC 60079-0 and may only be used with fixed installation. The user must ensure that the cable is sufficiently secured.
- 17.4 High or repeating charging processes must be excluded for use in EPL Ga.
- 17.5 The non-metallic surfaces of the load cells must be protected from mechanical hazards by the installation.

**18 Essential Health and Safety Requirements**

The Essential Health and Safety Requirements are covered by the standards listed under item 9. In addition to the Essential Health and Safety Requirements are covered by the standards listed under item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

The standard IEC 60079-7:2015 Ed. 5.1 used in the annex is technically identical to the EN Standard listed on the front page.

The standard IEC 60079-0:2017 Ed. 7 used in the annex is technically identical to the EN IEC standard listed on the front page. For this product is the standard IEC 60079-0:2017 in terms of safety equivalent to the harmonized standard EN IEC 60079-0:2018. The marking meets the requirements of Directive 2014/34/EU (see clause 5 of this Test Report).

**19 Drawings and Documents**

Drawings and documents are listed in the confidential report.

We confirm the correctness of the translation from the German original.  
In the case of arbitration only the German wording shall be valid and binding.

DEKRA Testing and Certification GmbH  
Bochum, 2021-06-07  
BVS-Hil/Kir A20190777


  
\_\_\_\_\_  
Managing Director



Page 4 of 4 of BVS 21 ATEX E 023 X – Jobnumber 341428900  
This certificate may only be reproduced in its entirety and without any change.

DEKRA Testing and Certification GmbH, Handwerkstr. 15, 70565 Stuttgart, Germany  
Certification body: Dimmendahlstr. 9, 44809 Bochum, Germany  
Phone +49.234.3696-400, Fax +49.234.3696-401, e-mail DTC-Certification-body@dekra.com

9.7 IECEx BVS 21.0024X



## IECEx Certificate of Conformity

---

**INTERNATIONAL ELECTROTECHNICAL COMMISSION**  
**IEC Certification System for Explosive Atmospheres**  
for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

---

Certificate No.:	IECEx BVS 21.0024X	Page 1 of 3	<a href="#">Certificate history</a>
Status:	Current	Issue No: 0	
Date of Issue:	2021-06-10		
Applicant:	<b>MinebeaMitsumi Inc.</b> 1-1-1 Katase Fujisawa-shi Kanagawa, 251-8531 Japan		
Equipment:	Load cell type M***-**** * * * * alternatively type PR **-**** * * *		
Optional accessory:			
Type of Protection:	Intrinsic Safety "i"; Protection by enclosure "t"; Increased Safety "e"		
Marking:	M***-**** * 0 * * * alternatively PR **-**** * * * Ex ia IIC T6/T4 Ga Ex ia IIIC T <sub>200</sub> 165°C Da  M***-**** * 2 * * * alternatively PR **-**** * * * Ex ec IIC T6/T4 Gc Ex tb IIIC T110°C Db		

Approved for issue on behalf of the IECEx Certification Body:

Position:

Signature:  
(for printed version)

Date:

**Jörg Koch**

Head of Certification Body

---





---

1. This certificate and schedule may only be reproduced in full.  
 2. This certificate is not transferable and remains the property of the issuing body.  
 3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.


Certificate issued by:

**DEKRA Testing and Certification GmbH**  
 Certification Body  
 Dinnendahlstrasse 9  
 44809 Bochum  
 Germany

DEKRA

On the safe side.



## IECEX Certificate of Conformity

---

Certificate No.: **IECEX BVS 21.0024X**

Date of issue: 2021-06-10

Manufacturer: **MinebeaMitsumi Inc.**  
1-1-1 Katase  
Fujisawa-shi  
Kanagawa, 251-8531  
**Japan**

Additional manufacturing locations:

**NMB-Minebea Thai Ltd.**  
5/2 Moo 8  
Phaholyothin Road Km.149  
T. Nikom Sang Ton-Eng  
A.Muang  
Lopburi Province 15000  
**Thailand**

**Minebea Electronics & Hi-tech Components (Shanghai) Ltd.**  
No.5202  
Lian Xi Rd.  
Jinze Town  
Qingpu District  
Shanghai 201721  
**China**

Page 2 of 3

Issue No: 0

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

**STANDARDS :**  
The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards


IEC 60079-0:2017	Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0	
IEC 60079-11:2011	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "I"
Edition:6.0	
IEC 60079-31:2013	Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2	
IEC 60079-7:2017	Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1	

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

**TEST & ASSESSMENT REPORTS:**  
A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:  
[DE/BVS/ExTR21.0028/00](#)

Quality Assessment Reports:  
[NL/DEK/QAR17.0006/02](#)                      [NL/DEK/QAR17.0007/02](#)                      [NL/DEK/QAR17.0008/02](#)

		<h2 style="margin: 0;">IECEX Certificate of Conformity</h2>	
Certificate No.:	<b>IECEX BVS 21.0024X</b>	Page 3 of 3	
Date of issue:	2021-06-10	Issue No: 0	
<b>EQUIPMENT:</b>			
Equipment and systems covered by this Certificate are as follows:			
<b>Subject and Type</b>			
See Annex			
<b>Listing of all components used referring to older standards</b>			
None			
<b>Description</b>			
<p>The load cells type M***-**** * 0 *** alternatively type PR **-**** ** E are designed for use in zone 0 and zone 20 (EPL Ga and Da) in the type of protection intrinsic safety "i". The load cells type M***-**** * 2 *** alternatively type PR **-**** ** are designed for use in zone 2 and zone 21 (EPL Gc and Db) in the type of protection increased safety "ec" and protection by enclosure "tb".</p> <p>The load cells consist of a solid metal block, which is provided with strain gauges. Depending on the type, the strain gauges are either completely encapsulated or the space is welded gas-tight with a metal plug.</p> <p>The metal housing of types M010, PR 40, M020, PR 43, M040, PR 44, M060 and PR 47 is made of aluminium.</p> <p>The metal housing of types M030, PR 54, M050, PR 57, M070, PR 53, M080, PR 55, M090, PR 58, M100, PR 77, M110, PR 79, M130 and PR 78 is made of chrome-nickel steel.</p>			
<b>Parameters</b>			
See Annex			
<b>SPECIFIC CONDITIONS OF USE: YES as shown below:</b>			
1 Special conditions for use to be listed in EU Type Examination Certificate			
1.1 The equipment is suitable for an ambient temperature range from -30 °C up to 40 °C for temperature class T6 and an ambient temperature range from -30 °C up to 70 °C for temperature class T4 or dust applications.			
1.2 The equipment has to be installed in such a way that any ignition hazards caused by impact or friction can be excluded for use in EPL Ga.			
1.3 The cable glands have been tested with a reduced tensile force according to section A.3.1 of IEC 60079-0 and may only be used with fixed installation. The user must ensure that the cable is sufficiently secured.			
1.4 High or repeating charging processes must be excluded for use in EPL Ga.			
1.5 The non-metallic surfaces of the load cells must be protected from mechanical hazards by the installation.			
2 Additional special conditions for use			
2.1 When used in gas group IIC, the permanently connected wire must be additionally protected against manual charging. Note included in the safety instructions, warning information on electrostatic discharge included on the type plate.			
<b>Annex:</b>			
<a href="#">BVS_21_0024X_Minebea_Annex.pdf</a>			



# IECEX Certificate of Conformity



**Certificate No.:** IECEX BVS 21.0024X  
**Annex**  
 Page 1 of 1

**Subject and Type**

Load cell type M\*\*\*-\*\*\*\* \* \* \* \* \*

- |          |   |
|----------|---|
| Asterisk | Description   |
| 1+2      | Type of load cell<br>M010, M020, M030, M040, M050, M060, M070, M080, M090, M100, M110, M130         |
| 3-6      | Capacity of the load cell in kg (depending on the type)<br>0005 5 kg<br>07.5 7.5 kg<br>5099 5099 kg |
| 7        | Accuracy (not Ex-relevant)  |
| 8        | Ex protection<br>0 Useable in Zone 0 and 20<br>2 Useable in Zone 2 and 21                           |
| 9+10     | Length of the permanently attached supply line in meter (depending on the type)                     |
| 11       | Not Ex-relevant   |

Alternatively type PR \*\*-\*\*\*\* \* \* \*

- |          |   |
|----------|---|
| Asterisk | Description   |
| 1+2      | Type of load cell<br>PR 40, PR 43, PR 54, PR 44, PR 57, PR 47, PR 53, PR 55, PR 58, PR 77, PR 79, PR 78 |
| 3-6      | Capacity of the load cell (depending on the type)   |
| 7-8      | Unit of the capacity value [kg] or [t]  |
| 9        | Ex protection<br>E Useable in Zone 0 and 20<br>w/o Useable in Zone 2 and 21                             |

**Parameters**

Non-intrinsically safe parameters (type M\*\*\*-\*\*\*\* \* 2 \*\* \* / PR \*\*-\*\*\*\* \* \*)

Rated voltage		30	VDC
Rated current		500	mA
Rated power		3.1	W

Intrinsically safe parameters (type M\*\*\*-\*\*\*\* \* 0 \*\* \* / PR \*\*-\*\*\*\* \* \* E)

Maximum input voltage	$U_i$	30	VDC
Maximum input current	$I_i$	500	mA
Maximum input power	$P_i$	1.8	W for T6 ( type PR53)
		1.95	W for T6 (all other types)
		4	W for T4 (all types)
The load cells do not contain any concentrated capacitances or inductances.			
Maximum internal capacitance	$C_i$	130	pF / m
Maximum internal inductance	$L_i$	0,95	μH / m



# IECEX Certificate of Conformity



**Certificate No.:** **IECEX BVS 21.0024X**  
**Annex**  
**Page 2 of 1**

Thermal parameters

Ambient temperature range / Temperature class / Surface temperature       $-30\text{ }^{\circ}\text{C} \leq T_{\text{amb}} \leq 40\text{ }^{\circ}\text{C}$  (T6)  
 $-30\text{ }^{\circ}\text{C} \leq T_{\text{amb}} \leq 70\text{ }^{\circ}\text{C}$  (T4 and dust)

Published by  
Minebea Intec GmbH | Meiendorfer Strasse 205 A | 22145 Hamburg, Germany  
Phone: +49.40.67960.303 | Email: [info@minebea-intec.com](mailto:info@minebea-intec.com)  
[www.minebea-intec.com](http://www.minebea-intec.com)

